



#### **D.5.8 Report on insulated core testing after aging**

##### **FULGOR (EL)**

Lead authors: Konstantinos Grivas (EL), Anastasia Moraiti (EL), George Georgallis (EL)



FLOTANT -Innovative, low cost, low weight and safe floating wind technology optimized for deep water wind sites, has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No.815289



### D.5.8 Report on insulated core testing after aging

**Project Acronym:** FLOTANT

**Project Title:** Innovative, low cost, low weight and safe floating wind technology optimized for deep water wind sites

**Project Coordinators:** The Oceanic Platform of the Canary Islands (PLOCAN)

**Program:** H2020-LC-SC3-2018

**Topic:** Developing solutions to reduce the cost and increase performance of renewable technologies

**Instrument:** Research & Innovation Action (RIA)

**Deliverable Code:** 220520\_FLT\_WP5\_D5.8\_V0.1

**Due date:** 31/05/2022

The FLOTANT Project owns the copyright of this document (in accordance with the terms described in the Consortium Agreement), which is supplied confidentially and must not be used for any purpose other than that for which it is supplied. It must not be reproduced either wholly or partially, copied or transmitted to any person without the authorization of PLOCAN. FLOTANT is a Cooperation Research Project funded by the European Union's Horizon 2020 research and innovation programme. This document reflects only the authors' views. The Society is not liable for any use that may be made of the information contained therein.



DISSEMINATION LEVEL	
PU: Public	X
PP: Restricted to other programme participants (including the Commission Services)	
RE: Restricted to a group specified by the consortium (including the Commission Services)	
CO: Confidential, only for members of the consortium (including the Commission Services)	

DOCUMENT HISTORY		
Edit./Rev.	Date	Name
Prepared	12/04/2022	Anastasia Moraiti & Konstantinos Grivas (FULGOR)
Checked	19/04/2022	George Georgallis (FULGOR)
Approved	20/05/2022	Alejandro Romero (PLOCAN)

DOCUMENT CHANGES RECORD			
Edit./Rev.	Date	Chapters	Reason for change
EL/0.0	19/04/2022	All	Original Version

## DISTRIBUTION LIST

Copy no.	Company/ Organization (country)	Name and surname
1	PLOCAN (ES)	Alejandro Romero-Filgueira
2	UNEXE (UK)	Lars Johanning, Philipp Thies, Chenyu Zhao
3	UEDIN (UK)	Henry Jeffrey, Paul Kerr
4	AIMPLAS (ES)	Ferrán Martí, Blai López
5	ITA-RTWH (DE)	Thomas Koehler, Dominik Granich, Oscar Bareiro
6	MARIN (NL)	Erik-Jan de Ridder
7	TFI (IE)	Paul McEvoy
8	ESTEYCO (ES)	Ángeles Ortega, Betriz García
9	INNOSEA (FR)	Rémy Pascal, Hélène Robic, Florian Surmont, Jordi Serret
10	INEA (SI)	Igor Steiner, Aleksander Preglej, Marijan Vidmar
11	TX (UK)	Sean Kelly
12	HB (UK)	Ian Walters
13	FULGOR (EL)	George Georgallis, Konstantinos Grivas, Anastasia Moraiti
14	AW (HR)	Miroslav Komlenovic
15	FF (ES)	Bartolomé Mas, Juanjo De La Cuesta
16	COBRA (ES)	Sara Muñoz, Gregorio Torres
17	BV (FR)	Claire-Julie , Jonathan Boutrot, Jonathan Huet, Jimena Reachì,



## Acknowledgements

Funding for the FLOTANT project (Grant Agreement No. 815289) was received from the EU Commission as part of the H2020 research and Innovation Program.

The help and support, in preparing the proposal and executing the project, of the partner institutions is also acknowledged: Plataforma Oceánica de Canarias (ES), The University of Exeter (UK), The University of Edinburgh (UK), AIMPLAS – Asociación de Investigación Materiales Plásticos y Conexas (ES), Rheinisch-Westfaelische Technische Hochschule Aachen (DE), Stichting Maritiem Research Instituut Nederland (NL), Technology From Ideas Limited (IE), Esteyco SA (ES), Innosea (FR), Inea Informatizacija Energetika Avtomatizacija DOO (SI), Transmission Excellence Ltd (UK), Hydro Bond Engineering Limited (UK), FULGOR S.A., Hellenic Cables Industry (EL), Adria Winch DOO (HR), Future Fibres (ES), Cobra Instalaciones y Servicios S.A (ES), Bureau Veritas Marine & Offshore Registre International de Classification de Navires et Plateformes Offshore (FR).



### Abstract

Floating Offshore Wind (FOW) turbines will require MV/HV dynamic power cables to interconnect arrays and to connect to the long length static export power cables, which transmit the power from the offshore substations to the onshore grid, highlighting the need for cable solutions with high performance and reliability, yet cost effective.

Whilst copper is the conventional conductor choice due to its higher conductivity and mechanical strength, aluminum conductors cores are increasingly used for static power cables due to their benefit regarding overall cable weight and material cost and therefore similar cost and weight reduction benefits are expected to be realized for dynamic power cables with aluminum or aluminum alloy conductors.



*A 3D rendering of the 66 kV dynamic power cable*

This deliverable will present the results of the two (2) year aging test of the insulated core according to Cigre Recommendations No.722 (Regime A). The assessment procedure comprises an accelerated aging protocol on sufficiently representative cable core samples followed by an assessment of the residual dielectric strength at the end of its design life. This testing procedure is recommended especially for dynamic cables with wet design, in order to demonstrate that the insulation system when saturated is capable of withstanding the electrical stresses during cable's lifetime.

## TABLE OF CONTENTS

1	Introduction .....	8
2	Test Report - Results .....	9
2.1	General description of the test object .....	10
2.2	Tests .....	10
2.2.1	Pre-Conditioning of the test objects .....	10
2.2.2	Accelerated ageing of dielectric.....	10
2.2.3	Measurement of residual dielectric strength .....	11
3	Conclusions .....	12
	ANNEX 1. INSTRUMENTATION USED FOR TESTS .....	13
	ANNEX 2. CABLE STRUCTURE .....	14
	ANNEX 3. PHOTOS AND DIAGRAMS .....	15

## LIST OF FIGURES

Figure 1.	Cable structure.....	14
Figure 2.	temperature recording of preconditioning.....	15
Figure 3.	Voltage & temperature recording of 1 <sup>st</sup> year of accelerated ageing .....	15
Figure 4.	Voltage & temperature recording of 2 <sup>nd</sup> year of accelerated ageing .....	15
Figure 5.	Voltage & temperature displays .....	16
Figure 6.	AC voltage step breakdown test .....	16

## 1 Introduction

A long-term water aging test of the insulated cable core, according to Cigre Recommendation TB 722, was performed to assess the feasibility of the wet cable design with aluminium conductors in sea environment (saline solution). This test is required in order to demonstrate that the insulation materials, when saturated, retain sufficient dielectric strength to operate at the intended design dielectric stress,  $E_{\text{design}}$ , of production cables when they are continuously immersed in sea water for the cable service life. It should also be noted that a successful aging test result for cores with aluminium conductors is applicable to cores with copper conductors but not the opposite.

The assessment procedure comprises an accelerated aging protocol on sufficiently representative cable samples followed by an assessment of the residual dielectric strength at the end of its design life. The most demanding and widely accepted wet aging protocol is the 50 Hz 2 years duration test.

Therefore, for the purposes of this Project, the procedure of the 2-year water aging test is chosen (Regime A, Cigre TB 722).

Details concerning the test objects and the test procedure can be found at the publicly available deliverable D3.3 *“Insulated core of dynamic 72.5kV cable for aging testing”*.

The results are presented in the following Chapter through the attached official test report of the Hellenic Cables’ submarine plant (Fulgor, Quality control department).

## 2 Test Report - Results

 	
<h1>TEST REPORT</h1>	
<b>No.</b>	243 / 00
<b>Issue date</b>	25/08/2021
<b>Manufacturer</b>	FULGOR S.A
<b>Test object</b>	SINGLE CABLE CORE
<b>Type</b>	1x240 mm <sup>2</sup> – Al/XLPE/CWS
<b>Rated voltage U<sub>0</sub>/U (U<sub>m</sub>)</b>	38/66 (72.5) kV
<b>Standard specifications</b>	CIGRE TB 722 APRIL 2018
<b>Test laboratories</b>	FULGOR S.A., Soussaki, Greece
<b>Range of tests performed</b>	Report on insulated core testing after aging
<b>Date of test</b>	05 MAY 2019 - 05 AUGUST 2021
<b>Test result</b>	All tests foreseen were carried out satisfactory and all measured values were compared with those data and values given by the above standard specifications and found to meet the requirements.
<div style="display: flex; justify-content: space-around;"> <div style="text-align: center;"> <p>FULGOR S.A. Quality Control Engineer</p>  <p>V.Souglakos</p> </div> <div style="text-align: center;"> <p>FULGOR S.A. Quality Control Manager</p>  <p>I. Ztoupis</p> </div> </div> <p><i>The measured values apply only to tested objects. Contents of this test report may not be reproduced fully or partially, without permission of the CABLE HELLENIC CABLES GROUP</i></p>	

## 2.1 General description of the test object

The test object was a single cable core with aluminium round compacted conductor, XLPE insulation and Copper Wires Screen. More details are given in Annex 2 – Drawing 1. The cable core was manufactured at FULGOR plant and the test was performed by FULGOR S.A, in FULGOR premises.

Brief information for cable is presented below:

**Test object:** Cable core

Type	1x240 mm <sup>2</sup> AL/XLPE/CWS
Rated voltage U <sub>0</sub> /U (U <sub>m</sub> )	38/66 (72.5) kV
Standard specification	CIGRE Recommendations No. 722
Manufacturer	FULGOR S.A.

## 2.2 Tests

### 2.2.1 Pre-Conditioning of the test objects

A description of the cable system under investigation is presented below.

**Start date:** 05/05/2019

**End date:** 26/05/2019

**Measuring equipment:**

Code No.	Type	Calibration expiry date
070-140	Temperature / Pressure /Voltage data logger	30/12/2021

**Test method:** Cigre TB 722 § 3.6.2

Two samples of approximate 160m each, were immersed in the tank and submitted to the pre-conditioning test.

Test conditions	Unit	Applied value	Required value
Temperature of water	°C	55 ± 5	55 ± 5
Salinity of water	%	~ 4.0	3 – 6
Duration	Hrs	>500	≥500
Hydrostatic Pressure	mbar	1000	900 - 1500

**Test result:** When the test time had elapsed for the preconditioning test the test objects proceeded to the accelerated ageing test.

**Evaluation of test result:** PASS

### 2.2.2 Accelerated ageing of dielectric

**Start date:** 20/06/2019

**End date:** 29/07/2021

**Measuring equipment:**

Code No.	Type	Calibration expiry date
070-140	Temperature / Pressure /Voltage data logger	30/12/2021
070-008	AC Voltage test System 60kV	24/05/2023

**Test method:** Cigre TB 722 § 3.6.3, Regime A

At the end of the preconditioning, the two samples, approximate 160m each, proceeded to the accelerated ageing test. After the completion of 1st year of ageing, the remaining test object, approximate 160m, proceeded to the 2nd year of accelerated ageing test with the same test conditions.

Test conditions	Unit	Applied value	Required value
Voltage test	kV	54 ± 3%	54 ± 3%
Frequency	Hz	50	50
Temperature of water	°C	40 ± 5	40 ± 5
Salinity of water	%	~ 4.0	~ 4.0
Duration of 1 <sup>st</sup> year	Hrs	>8.750	>8.750
Duration of 2 <sup>nd</sup> year	Hrs	>17.500	>17.500

**Test result:** After the completion of each year of accelerated ageing, test objects were removed from the tank to assess the residual dielectric strength. The first sample had been subjected to more than 8.750h ageing and the second to more than 17.500h ageing.

**Evaluation of test result:** PASS

### 2.2.3 Measurement of residual dielectric strength

**Start date:** 11/07/2020

**End date:** 05/08/2021

**Measuring equipment:**

Code No.	Type	Calibration expiry date
070-001	600kV AV voltage measuring system	23/05/2023
071-001	Optical measuring system	02/07/2022

**Test method:** Cigre TB 722 § 3.6.4 (Table 3.6) and HD 605 § 5.4.15.3.4.

After the completion of each year of accelerated ageing, the test objects were tested to smaller samples in order to assess the residual dielectric strength with AC voltage step breakdown test according to Cigre TB 722 §3.6.4.2 (Table 3.6) & HD 605 § 5.4.15.3.4.

Test conditions	Unit	Applied value	Required value
Voltage test	kV	54 ± 3%	54 ± 3%
Frequency	Hz	50	50
Temperature of water	°C	40 ± 5	40 ± 5
Salinity of water	%	~ 4.0	~ 4.0

**Test Result:** The test results for step breakdown complied with the requirements given in the

tables below.

- 1<sup>st</sup> year of accelerated ageing
  - Six (6) samples were tested and the residual dielectric strength exceeded 32.7 kV/mm in all.
- 2<sup>nd</sup> year of accelerated ageing
  - Six (6) samples were tested and the residual dielectric strength exceeded 32.7 kV/mm in all.

**Evaluation of test result: PASS**

### 3 Conclusions

This work has offered a summary of the main results regarding the performance of an insulated aluminium power core designed for dynamic applications, under applied electrical stresses and wet conditions. Based on the selected applied voltage level ( $54 \pm 3\%$  kV), the test results for step breakdown fully complied with the requirements of the Test Regime A. This is encouraging, as the proposed wet design for insulated dynamic power cores with aluminium conductors can be implemented for deep water floating wind applications. Taking into account that the proposed cable design is low weight and low cost compared to the conventional copper one, this deliverable contributes to the overall reduction of the LCoE for floating wind applications.

## ANNEX 1. INSTRUMENTATION USED FOR TESTS

Code No.	Type	Required value
070-001	600 kV AC voltage measuring system	23/05/2023
070-008	AC voltage test system 60 kV	24/05/2023
070-140	Temperature / Pressure / Voltage data logger	30/12/2021
071-001	Optical measuring system	01/07/2022

## ANNEX 2. CABLE STRUCTURE




Figure 1. Cable structure

## ANNEX 3. PHOTOS AND DIAGRAMS




Figure 2. temperature recording of preconditioning




Figure 3. Voltage & temperature recording of 1<sup>st</sup> year of accelerated ageing




Figure 4. Voltage & temperature recording of 2<sup>nd</sup> year of accelerated ageing



Figure 5. Voltage & temperature displays



Figure 6. AC voltage step breakdown test